

**HAUSER LAKE WATER ASSOCIATION, INC. (PWS #1280084)  
SOURCE WATER ASSESSMENT REPORT**

---

**August 27, 2001**



**State of Idaho  
Department of Environmental Quality**

**Disclaimer:** This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on the data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the state of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

## Executive Summary

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the act. This assessment is based on a land use inventory of the designated assessment area, sensitivity factors associated with the wells, and aquifer characteristics.

This report, *Source Water Assessment for Hauser Lake Water Association, Inc. (PWS #1280084)*, describes the public drinking water system, the boundaries of the zones of water contribution, and the associated potential contaminant sources located within these boundaries. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. **The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The Hauser Lake Water Association, Inc. drinking water system consists of two wells. The wells serve a population of 950 people in the community of Hauser, Idaho. The first well was drilled in 1967 and the second well was drilled in 1974. The wells are located in a wellfield, indicating that conditions in one well reflect the conditions in the other well. Water samples representative of the wellfield have been satisfactory. The water system is currently not experiencing water quality issues.

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

Hauser Lake Water Association, Inc. should focus source water protection activities on maintaining current water quality. The system should continue to clean the well houses on a regular basis and ensure that no hazardous materials are stored near the wells. The water system should also develop a source water protection plan that addresses public education and contingency planning. Local residents should be made aware of the location of the wells and the location of the wells’ source water assessment areas. They should be advised of methods for the proper disposal of household hazardous wastes in these areas and of septic system maintenance procedures. The water system should draw up a contingency plan that outlines emergency response activities and identifies an alternative source of water should one become necessary.

The large number of public water systems in Idaho drawing water from the Rathdrum Prairie Aquifer should consider forming a regional group to represent their interests before state, county and municipal governing bodies when regulatory tools like zoning overlays, or enactment of building codes are the most appropriate ground water protection measures. Partnerships with state and local agencies and industry groups should be established and are critical to success. Due to the time involved with the movement of ground water, source water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term.

A community with a fully developed source water protection program will incorporate many strategies. For assistance in developing protection strategies, please contact your regional Idaho Department of Environmental Quality office or the Idaho Rural Water Association.

## **SOURCE WATER ASSESSMENT FOR HAUSER LAKE WATER ASSOCIATION, INC.**

### **Section 1. Introduction- Basis for Assessment**

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this source means.** A map showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are attached.

#### **Level of Accuracy and Purpose of the Assessment**

The Idaho Department of Environmental Quality (DEQ) is required by the U.S. Environmental Protection Agency (EPA) to assess the over 2,900 public drinking water sources in Idaho for their relative susceptibility to contaminants regulated by the Safe Drinking Water Act. This assessment is based on a land use inventory of the delineated assessment area, sensitivity factors associated with the wells, and aquifer characteristics. All assessments must be completed by May of 2003. The resources and time available to accomplish assessments are limited. Therefore, an in-depth, site-specific investigation to identify each significant potential source of contamination for every public water system is not possible. **This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The ultimate goal of this assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. The Idaho Department of Environmental Quality (DEQ) recognizes that pollution prevention activities generally require less time and money to implement than treating a public water supply system once it has been contaminated. DEQ encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a source water protection program should be determined by the local community based on its own needs and limitations. Wellhead or source water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

## **Section 2. Conducting the Assessment**

### **General Description of the Source Water Quality**

Hauser Lake Water Association, Inc. serves a community of approximately 950 people, located in Hauser, Idaho (Figure 1). The Hauser Lake Water Association, Inc. is comprised of two wells.

The water system is currently not facing water quality issues. The system samples monthly for total coliform bacteria. All samples taken from the system are representative of both wells. The last positive sample was collected on 10/11/99. The system's water is not treated, as treatment is not necessary or required. The water system samples annually for nitrate and every nine years for nitrite. Both are within acceptable limits. Other inorganic chemicals are monitored every three years. Traces of barium, arsenic, cadmium, chromium, fluoride, chloride and zinc have been detected upon testing. All were well below maximum contaminant levels. On 7/26/93 a water sample revealed dichloromethane at .5µg/L and tetrachloroethylene at 1.0µg/L. The maximum contaminant level for both chemicals is 5.0µg/L. Because these chemicals were only detected a single time and follow-up samples were negative, it is most likely that the presence of the chemicals was due to sampling error. The water system has obtained waivers for synthetic organic chemicals and volatile organic chemicals. Lead and copper levels in the water system are measured every three years and are below maximum contaminant levels. Radiological levels are measured every four years and are also at acceptable levels.

### **Defining the Zones of Contribution- Delineation**

The delineation process establishes the physical area around a well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time of travel zones (zones indicating the number of years necessary for a particle of water to reach a well) for water in the aquifer. DEQ used a refined computer model approved by the EPA in determining the three-year (Zone 1B), six-year (Zone 2), and ten-year (Zone 3) times-of-travel (TOT) for water associated with the Rathdrum Prairie aquifer in the vicinity of Hauser, Idaho. The computer model used site specific data, assimilated by DEQ from a variety of sources including the city and other local well logs. The delineated source water assessment areas for the Hauser Lake Water Association, Inc. can best be described as a slight curve extending from the wellhead north for approximately one mile. The assessment area for Well 2 is slightly longer than the assessment area for Well 1. The actual data used by DEQ in determining the source water assessment delineation area are available upon request.

### **Identifying Potential Sources of Contamination**

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act and has a sufficient likelihood of releasing such contaminants at levels that could pose a concern relative to drinking water sources. The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of ground water contamination. The locations of potential sources of contamination within the delineation area were obtained by field surveys conducted by DEQ and from available databases.

The dominant land use in the area surrounding the Hauser Lake Water Association, Inc. drinking water system is rural residential.

It is important to understand that a release may never occur from a potential source of contamination provided best management practices are used at the facility. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation. There are a number of methods that water systems can use to work cooperatively with potential sources of contamination, such as educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

### Contaminant Source Inventory Process

A two-phased contaminant inventory of the study areas was conducted during May and June of 2001. The first phase involved identifying and documenting potential contaminant sources within the Hauser Lake Water Association, Inc. source water assessment areas through the use of computer databases and Geographic Information System maps developed by DEQ. The second, or enhanced, phase of the contaminant inventory involved contacting the operator to validate the sources identified in phase one and to add any additional potential sources in the area.

There is one documented potential contaminant site located within the delineated source water areas (Table 1). The site is an auto repair shop located in the wells' ten-year time of travel zone (Figure 1).

**Table 1. Hauser Lake Water Association, Inc. Potential Contaminant Inventory**


SITE #	Source Description <sup>1</sup>	TOT Zone <sup>2</sup> (years)	Source of Information	Potential Contaminants <sup>3</sup>
1	BML	10	Database Search	VOC, SOC

<sup>1</sup> BML = business mailing list

<sup>2</sup> TOT = time of travel (in years) for a potential contaminant to reach the wellhead

<sup>3</sup> IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

Figure 1. Geographic Location of the Hauser Lake Water Association, Inc. Wells







### **Section 3. Susceptibility Analysis**

The susceptibility of the source to contamination was ranked as high, moderate, or low risk according to the following considerations: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. The following summaries describe the rationale for the susceptibility ranking.

#### **Hydrologic Sensitivity**

The wells' hydrologic sensitivity is high. This reflects porous nature of the soils associated with the Rathdrum Prairie aquifer and the lack of significant confining layers retarding the vertical transport of contaminants.

#### **Well Construction**

Well construction directly affects the ability of the wells to protect the aquifer from contaminants. Lower scores imply a system that can better protect the water. The Hauser Lake Water Association, Inc. drinking water system consists of two wells that extract ground water for domestic use. Water extraction is monitored and managed by the system operator.

##### Well 1

The well's system construction score is moderate. The well was drilled in 1967 to a depth of 213'. A 12-inch steel casing was used. The Idaho Department of Water Resources (IDWR) *Well Construction Standards Rules (1993)* require all public water systems (PWSs) to follow DEQ standards as well. IDAPA 58.01.08.550 requires that PWSs follow the *Recommended Standards for Water Works (1997)* during construction. Various aspects of the standards can be assessed from well logs. Table 1 of the *Recommended Standards for Water Works (1997)* states that 12-inch steel casing requires a thickness of 0.375 inches. Well 1 uses .330" thick casing. The casing is followed by a stainless steel well screen from 188' to 208'. The well was sealed to 10' with cement and from 10' to 35' with bentonite. The well is located outside the 100-year floodplain.

##### Well 2

This well was drilled in 1974. It was also assigned a moderate system construction score, but unlike Well 1, Well 2 uses a casing that meets thickness standards. The well casing is 16 inches in diameter and .375" thick. The casing extends to 191' and is followed by a stainless well screen to 211'. The screen terminates in clay. The well was sealed to 20' with cement grout and is located outside of the 100-year floodplain.

#### **Potential Contaminant Source and Land Use**

The source water assessment areas for the wells are virtually identical, with Well 2's source water assessment area being slightly longer than Well 1's. There is only one contaminant site located within the wells' source water assessment areas. The site is an auto repair shop located in the wells' 10-year time of travel zone. The wells' potential contaminant/land use scores are low in all chemical categories.



## Final Susceptibility Ranking

In terms of the total susceptibility score, it can be seen from Table 2 that the wells showed a moderate overall susceptibility in all chemical categories.

**Table 2. Summary of Hauser Lake Water Association, Inc. Susceptibility Evaluation**

Well	Susceptibility Scores <sup>1</sup>									
	Hydrologic Sensitivity	Contaminant Inventory				System Construction	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
1	H	L	L	L	L	H	M	M	M	M
2	H	L	L	L	L	M	M	M	M	M

<sup>1</sup>H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility  
IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

## Susceptibility Summary

The Hauser Lake Water Association, Inc. drinking water system is currently not threatened by significant potential contaminant sites.

## Section 4. Options for Source Water Protection

The susceptibility assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what the susceptibility ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

An effective source water protection program is tailored to the particular local source water protection area. The State of Idaho and local health districts have instituted enhanced protection of the ground water in the Rathdrum Prairie Aquifer because of its high use and uniquely pristine water quality. The protections are generally aquifer wide and are not aimed at zones of contribution to a specific well or water system. *The Spokane Valley-Rathdrum Prairie Atlas*, sent to water systems on the prairie when they were invited to perform an enhanced contaminant inventory, describes some of the regional protection measures.

The 186 public water systems in Idaho that draw water from the Rathdrum Prairie Aquifer should consider forming a regional group to represent their interests before state, county and municipal governing bodies when regulatory tools like zoning overlays, or enactment of building codes are the most appropriate ground water protection measures. These types of measures could be used to protect the capture zones of a specific system or group of wells that could be put at risk from local land use changes.

Hauser Lake Water Association, Inc. should focus source water protection activities on implementation of practices aimed at maintaining current water quality. The water system should continue their practice of cleaning the well houses regularly and storing hazardous materials and equipment outside of the well lots. The system should develop a source water protection plan that describes their maintenance practices and addresses public education and emergency response planning. The wells' locations and the locations of the wells' source water assessment areas should be made known to local residents. Residents should be advised of methods for the proper use, storage and disposal of household hazardous wastes. They should also be instructed on septic system maintenance procedures to protect groundwater from bacterial and/or nitrate contamination. Hauser Lake Water Association, Inc. should develop a contingency plan that lists emergency response resources and identifies an alternative source of water should the wells ever become contaminated. Partnerships with state and local agencies and industry groups should be established and are critical to success. Due to the time involved with the movement of ground water, wellhead protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term.

## **Assistance**

Public water supplies and others may call the following IDEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the IDEQ office for preliminary review and comments.

Coeur d'Alene Regional IDEQ Office (208) 769-1422

State IDEQ Office (208) 373-0502

Website: <http://www.deq.state.id.us>

Water suppliers serving fewer than 10,000 persons may contact John Bokor, Idaho Rural Water Association, at 1-800-962-3257 for assistance with wellhead protection strategies.

## References Cited

Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 1997. "Recommended Standards for Water Works."

Idaho Department of Environmental Quality, 1997. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.

Idaho Department of Water Resources, 1993. Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules. IDAPA 37.03.09.

# **Attachment A**

## **Hauser Lake Water Association, Inc. Susceptibility Analysis Worksheets**

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.2)
- 2) Microbial Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.35)

Final Susceptibility Scoring:

- 0 - 5 Low Susceptibility
- 6 - 12 Moderate Susceptibility
- > 13 High Susceptibility

1. System Construction		SCORE			
Drill Date	06/30/1967				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	2000			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	NO	2			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		4			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		6			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	OTHER	0	0	0	0
Farm chemical use high	NO	0	0	0	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		0	0	0	0
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	NO	0	0	0	0
(Score = # Sources X 2 ) 8 Points Maximum		0	0	0	0
Sources of Class II or III leachable contaminants or	NO	0	0	0	
4 Points Maximum		0	0	0	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B Less Than 25% Agricultural Land		0	0	0	0
Total Potential Contaminant Source / Land Use Score - Zone 1B		0	0	0	0
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	NO	0	0	0	
Sources of Class II or III leachable contaminants or	NO	0	0	0	
Land Use Zone II Less than 25% Agricultural Land		0	0	0	
Potential Contaminant Source / Land Use Score - Zone II		0	0	0	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	YES	0	1	1	
Sources of Class II or III leachable contaminants or	YES	0	1	1	
Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0	
Total Potential Contaminant Source / Land Use Score - Zone III		0	2	2	0
Cumulative Potential Contaminant / Land Use Score		0	2	2	0
4. Final Susceptibility Source Score		10	10	10	10
5. Final Well Ranking		Moderate	Moderate	Moderate	Moderate



1. System Construction		SCORE			
Drill Date	12/24/1974				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	2000			
Well meets IDWR construction standards	YES	0			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	NO	2			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		3			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		6			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	OTHER	0	0	0	0
Farm chemical use high	NO	0	0	0	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		0	0	0	0
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	NO	0	0	0	0
(Score = # Sources X 2 ) 8 Points Maximum		0	0	0	0
Sources of Class II or III leachable contaminants or	NO	0	0	0	
4 Points Maximum		0	0	0	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B Less Than 25% Agricultural Land		0	0	0	0
Total Potential Contaminant Source / Land Use Score - Zone 1B		0	0	0	0
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	NO	0	0	0	
Sources of Class II or III leachable contaminants or	NO	0	0	0	
Land Use Zone II Less than 25% Agricultural Land		0	0	0	
Potential Contaminant Source / Land Use Score - Zone II		0	0	0	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	YES	0	1	1	
Sources of Class II or III leachable contaminants or	YES	0	1	1	
Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0	
Total Potential Contaminant Source / Land Use Score - Zone III		0	2	2	0
Cumulative Potential Contaminant / Land Use Score		0	2	2	0
4. Final Susceptibility Source Score		9	9	9	9
5. Final Well Ranking		Moderate	Moderate	Moderate	Moderate

# Potential Contaminant Inventory

## List of Acronyms and Definitions

**AST (Aboveground Storage Tanks)** – Sites with aboveground storage tanks.

**Business Mailing List** – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

**CERCLIS** – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as **ASuperfund®** is designed to clean up hazardous waste sites that are on the national priority list (NPL).

**Cyanide Site** – DEQ permitted and known historical sites/facilities using cyanide.

**Dairy** – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

**Deep Injection Well** – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

**Enhanced Inventory** – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

**Floodplain** – This is a coverage of the 100year floodplains.

**Group 1 Sites** – These are sites that show elevated levels of contaminants and are not within the priority one areas.

**Inorganic Priority Area** – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

**Landfill** – Areas of open and closed municipal and non-municipal landfills.

**LUST (Leaking Underground Storage Tank)** – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

**Mines and Quarries** – Mines and quarries permitted through the Idaho Department of Lands.)

**Nitrate Priority Area** – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

**NPDES (National Pollutant Discharge Elimination System)**

– Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

**Organic Priority Areas** – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

**Recharge Point** – This includes active, proposed, and possible recharge sites on the Snake River Plain.

**RICRIS** – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

**SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities)** – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

**Toxic Release Inventory (TRI)** – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

**UST (Underground Storage Tank)** – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

**Wastewater Land Applications Sites** – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

**Wellheads** – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

**NOTE:** Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.